

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0078:176 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: ADEMCO, 165 Eileen Way, Syosset, NY 11891
Contact: David Kalmus (516) 921-6704

DESIGN: Model 5120XM fire alarm control unit. Automatic, manual, noncoded, local, remote station, central station, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. Minimum system components:

5120XM	Control Unit/DACT
1451	Transformer
6137, 6137-R, 6139, 6139-R	Keypad

RATING: Primary 120 VAC, 18/30 VAC Secondary, 12/24 VDC Standby

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and indicating devices.

This control unit can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: For **Fire Alarm Verification Feature**, the maximum Retard/Reset/Restart period must be adjusted to 30 seconds or less.

*Corrected 07-20-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager